




# BS 6375-1:2015



**Test of: Side Hung Next To Direct Glazed Window**

**Performance of windows & doors - Part 1: Weathertightness**

A Report To:  
Aluminos Cortizo  
Extramundi, S/N. 15910 – Padrón (A Coruña) España

Document Reference:  
WIL 399383

Date: 27/06/2018

Copy: 1

Issue No.: 2

Page 1

Testing  
Advising  
Assuring



## TEST CONCLUSIONS

Samples of:  
 Manufacturer           Aluminios Cortizo  
 Product                 Window  
 Model                    Side Hung Next To Direct Glazed Window

have been tested in accordance with: BS6375-1:2015  
 By Exova Wednesbury, a UKAS accredited Testing Laboratory (No. 0621)

At Unit 3 Wednesbury One, Black Country New Road, Wednesbury, WS10 7NZ.  
 Results and comments as detailed below:

Clause No.	Description	Classification
<b>4</b>	<b>Exposure category and classification</b>	<b>2400</b>
6	Test for air permeability (to EN1026)	CLASS 4
7	Test for watertightness (to EN1027)	CLASS E1200
8	Test for resistance to wind (to EN12211)	CLASS CE2400

No inferences can be made regarding performance against other requirements of this standard

Tests marked "N/A" are not applicable to the sample under test.  
 Tests marked "N/T" were not applied to the sample under test